

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3175-1539:102 Page 1 of 1

**CATEGORY:** Air Filter Units

**LISTEE:** Filtration Group Inc., 912 E. Washington St., Joliet, IL 60433  
Contact: \*Joseph Benoit (815) 774-1289 Fax (815) 726-2765

**DESIGN:** Model "Extended Surface Pleated Air Filter Standard", "Extended Surface Pleated Air Filter High Capacity", and "Pleated Air Filter" dry type, throw-away air filter units. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Class I and II  
Maximum Thickness: 4"

**INSTALLATION:** In accordance with listee's printed installation instructions and applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, classification and UL label.

**APPROVAL:** Listed as Class I and II, dry type throw-away air filter units for use in heating, ventilating, and air conditioning systems.

\*Rev. 06-21-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 13, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**